

Project: Revise Research ERU Intakes

Solicitation Number: VA263-13-B-1736

Project Number: 636A8-13-013

The following questions have been asked by potential offerors, relative to the aforementioned solicitation. Answers are supplied directly below the questions.

1) Will we need to have hand rails on the new cat walks that we are providing?

Answer: No

2) Will the holes in the existing steel beams for the new catwalk beams need to be cold galvanized after they are drilled?

Answer: Yes

3) Are you going to provide specification sections for the structural steel and grating?

Answer: No specifications will be issued. The steel grating is described on Sheet 1-S1 under Key Note #1. The steel beams are described on 1-S0.

Additionally, the attached revised structural drawing is henceforth a part of the construction bid documents for this project.

Regards,

Ben Smith